



NOTES:

1. PROVIDE A "FRANKLIN GREEN 80% GLOSS" RECEPTACLE POST (ARLINGTON INDUSTRIES #GP26B OR APPROVED EQUAL) WITH BLACK GROUND FAULT INTERRUPTING RECEPTACLE (HUBBELL GF5362 OR APPROVED EQUAL) AND IN-USE WEATHER PROOF COVER (ARLINGTON INDUSTRIES #60VC OR APPROVED EQUAL)

NOTE:

THIS DETAIL TO BE USED IN DOWNTOWN FRANKLIN GATEWAY CORRIDORS AND CONNECTOR STREETS.

N.T.S

CITY OF FRANKLIN		 CITY ENGINEER	7/1/2017
PLANTER RECEPTACLE DETAIL			DATE
DWG. NO. L-5	EFFECTIVE DATE: 7/1/2017	 ASST. DIRECTOR OF ENG.	7/1/2017
			DATE