



GENERAL NOTES

- 1) ALLEY RADIUS 10FT (UNLESS OTHERWISE SHOWN ON CONTRACT PLANS).
- 2) NO TRANSVERSE SLOPE ON THE RAMP OR SIDEWALK SHALL EXCEED 8.3% (12:1) IN THE DIRECTION OF TRAVEL
- 3) SEE PAVEMENT SECTION FOR TYPICAL ALLEY.
- 4) 5' MINIMUM SIDEWALK WITH A 1.5% DESIRABLE AND ABSOLUTE MAXIMUM OF 2% THROUGH DRIVEWAYS.
- 5) DETECTABLE WARNING SHALL EXTEND THE FULL WIDTH OF THE CURB RAMP AND SHOULD EXTEND ONLY 2 FEET IN THE DIRECTION OF TRAVEL.
- 6) 6" MIN BASE STONE (303-01 MINERAL AGGREGATE, TYPE "A" BASE, GRADING "D" REQUIRED UNDER ALL ALLEY CONCRETE APRON)

N.T.S

CITY OF FRANKLIN

ALLEY APPROACH APRON

DWG. NO. SD-5

EFFECTIVE DATE: 7/1/2017

Paul P. Hoyle 7/1/2017
CITY ENGINEER DATE

Stephanie M. Weston 7/1/2017
ASST. DIRECTOR OF ENG. DATE