



SECTION A-A

GENERAL NOTES

1. 5' MINIMUM SIDEWALK WITH A 1.5% DESIRABLE AND ABSOLUTE MAXIMUM OF 2% THROUGH DRIVEWAYS.
2. 4" MIN BASE STONE (303-01 MINERAL AGGREGATE, TYPE "A" BASE, GRADING "D") REQUIRED UNDER ALL DRIVEWAYS
3. RESIDENTIAL DRIVEWAYS SHALL BE A MIN 6" OF CLASS "A" CONCRETE WITH SYNTHETIC FIBER REINFORCEMENT. COMMERCIAL DRIVEWAYS SHALL BE A MIN 8" OF CLASS "A" CONCRETE WITH SYNTHETIC FIBER REINFORCEMENT.
4. DETECTABLE WARNING SURFACES SHOULD NOT BE PROVIDED AT CROSSINGS OF RESIDENTIAL DRIVEWAYS. DETECTABLE WARNING SURFACES SHOULD BE PROVIDED ON COMMERCIAL DRIVEWAYS WITH YIELD OR STOP CONTROL AT THE JUNCTION BETWEEN THE PEDESTRIAN ROUTE AND THE VEHICULAR ROUTE.
5. DETECTABLE WARNING SURFACES SHALL BE YELLOW (ADA SOLUTIONS, INC. OR APPROVED EQUAL) CAST IN PLACE AND SHALL EXTEND THE FULL WIDTH OF THE CURB RAMP (EXCLUSIVE OF FLARED SIDES) AND SHOULD EXTEND ONLY 2 FEET IN THE DIRECTION OF TRAVEL.

N.T.S

CITY OF FRANKLIN		 CITY ENGINEER	7/1/2017 DATE
LOWERED CONCRETE DRIVEWAY (WITHOUT GRASS STRIP)			 ASST. DIRECTOR OF ENG.
DWG. NO. RP-7	EFFECTIVE DATE: 7/1/2017		