



GENERAL NOTES

1. CLASS "A" CONCRETE, MINIMUM 28 DAY COMPRESSIVE STRENGTH OF 3,000 PSI WITH SYNTHETIC FIBER REINFORCEMENT.
2. DESIRABLE SIDEWALK CROSS SLOPE IS 1.5%, ABSOLUTE MAXIMUM IS 2.0%.
3. ALSO SEE EXPANSION JOINT DETAIL
4. 4" MIN BASE STONE (303-01 MINERAL AGGREGATE, TYPE "A" BASE, GRADING "D" REQUIRED UNDER ALL SIDEWALKS.

N.T.S

CITY OF FRANKLIN

TYPICAL 5' CONCRETE SIDEWALK

DWG. NO. RP-8

EFFECTIVE DATE: 7/1/2017

Paul P. Hoyle 7/1/2017
CITY ENGINEER DATE

Stephanie M. Martin 7/1/2017
ASST. DIRECTOR OF ENG. DATE