



GENERAL NOTES

1. CLASS "A" CONCRETE, MINIMUM 28 DAY COMPRESSIVE STRENGTH OF 3,000 PSI WITH SYNTHETIC FIBER REINFORCEMENT.
 2. DESIRABLE SIDEWALK CROSS SLOPE IS 1.5%, ABSOLUTE MAXIMUM IS 2.0%.
 3. ALSO SEE EXPANSION JOINT DETAIL
 4. 4" MIN BASE STONE (303-01 MINERAL AGGREGATE, TYPE "A" BASE, GRADING "D" REQUIRED UNDER ALL SIDEWALKS.
- N.T.S

CITY OF FRANKLIN

TYPICAL CONCRETE 10'-12' MULTI-USE TRAIL

Paul P. Hoyle
CITY ENGINEER

7/1/2017
DATE

DWG. NO. RP-9

EFFECTIVE DATE: 7/1/2017

Stephan M. Martin
ASST. DIRECTOR OF ENG.

7/1/2017
DATE