

List of Releases

Date/Time	Location	Status	Duration	Estimated Volume	Cause	Detailed Report
1/31/2018 @ 7 am	920 Market St	Resolved	1 Hour and 5 Minutes	9,750 Gallons	Air Relief Valve malfunctioned	920 Market St
3/15/2018 @ 12:30 pm	1014 Columbia Ave	Resolved	40 Minutes	200 Gallons	Infrastructure Failure	1014 Columbia Ave
6/21/2018 @ 5:50 pm	4321 Carothers Parkway	Resolved	N/A	20 Gallons	Rags	4321 Carothers Parkway
8/14/2018 @ 2:00 pm	1725 Mallory Lane	Resolved	45 Minutes	60 Gallons	Broken 3/8" ball valve on bypass pump	1725 Mallory Lane

List of Overflows

Date/Time	Location	Status	Duration	Estimated Volume	Cause	Detailed Report
2/11/2018 @ 9:15 am	537 Ploughmans Bend	Resolved	15 Hours 50 Minu tes	48,000 Gallons	Wet Weather	537 Ploughmans Bend Dr
3/1/2018	330 11th Ave N	Resolved	11 Hours 25 Minu tes	11,000 Gallons	Wet Weather	330 11th Ave N