

City of Franklin Addendum No. 1 to

Purchasing Office Solicitation No.: 2020-005

1. Solicitation identified: This Addendum No. 1 applies to the following procurement solicitation:

PVC pipe and ductile iron fittings

Purchasing Office Solicitation No.: 2020-005

2. Notice to Bidders publication date: **June 27, 2019**
3. Solicitation release date: **June 27, 2019**
4. Addendum No. 1 release date: **July 2, 2019**
5. Deadline for optional submittal in writing of questions seeking to revise or clarify any aspect of this procurement solicitation: **July 3, 2019, 2:00 p.m. Central Time**
6. Bids submittal deadline and scheduled opening: **July 11, 2019, 2:00 p.m. Central Time**
7. Tentative date of release of City's tabulation of bids received and notice of intent to award: **August 5, 2019**
8. Tentative date of award: Meeting of Board of Mayor and Aldermen at which is tentatively scheduled to be awarded the selection of the lowest and best responsive and responsible bid: **August 13, 2019**

9. Addendum:

In reference to the City of Franklin's June 27, 2019 Purchasing Office Solicitation No. 2020-005 for the supply and delivery of PVC pipe and ductile iron fittings, the City has been asked certain questions about the solicitation by one or more vendors who are potential bidders.

The purpose of this Addendum No. 1 is to announce the City's responses to the questions that have been asked to date.

Please note that the submittal deadline and scheduled opening of all bids received remains unchanged and is:

July 11, 2019, 2:00 p.m. Central Time

Below are the questions asked to date and the City's responses thereto:

City of Franklin Addendum No. 1 to

Purchasing Office Solicitation No.: 2020-005

Q1: Are the reclaimed valve boxes to be Bouchard 8006?

A1: Yes.

Q2: Line item 12, 5¼ purple fire hydrant: (a) Is this a standard 3'6" bury hydrant like Franklin Water uses? (b) Will this hydrant be used to fight fires? If not, it can be ordered without a pumper nozzle so a fire department can't connect to it.

A2: (a) Yes. (b) No, this hydrant will not be used to fight fires so it should exclude a pumper nozzle but it should include a steamer nozzle.

Q3: Line item 13: (a) What type of valve boxes are being requested? (b) How deep?

A3: (a) Bouchard 8006. (b) Three (3) feet.

Q4: Line items 16, 18 and 20, Megalug Gland pack for PVC for 6", 8", and 12": Does this mean the megalug and the nut, bolt, gasket set (accessories) added together?

A4: Yes.

10. Acknowledge addendum: Bidders shall acknowledge this addendum on the Bid Submittal Form in the space to the right of the text on that form that reads, "Acknowledge any and all issued addenda to this solicitation."

11. Questions, requests for clarifications, and requests to revise the procurement solicitation; addenda: To ask questions, to request clarifications about any aspect of this procurement solicitation, or to request revisions to the procurement solicitation prior to the deadline for optional submittal in writing of questions seeking to revise or clarify any aspect of the procurement solicitation, please contact:

City of Franklin Purchasing Office
Franklin City Hall, Suite 107
109 3rd Ave. South
Franklin, TN 37064
purchasing@franklin.tn.gov
Tel: 615/550-6692
Fax: 615/550-0079

Depending upon the inquiry, the City may request that the question, request for clarification, or request for revision be submitted in writing, whereupon the City may choose to announce the inquiry and the City's response thereto.

12. Communication with City during procurement phase: Any questions about either the content of or the procurement process pertaining to this procurement solicitation should be addressed as described above. Until the procurement award has been made, vendors shall not communicate about either the content of or the procurement process pertaining to this procurement solicitation with any official, employee or other representative of the City except through the City's Purchasing Office. The City reserves the right to disqualify any vendor that initiates unauthorized communication with the City during the procurement phase.