

City of Franklin Addendum No. 2 to

Purchasing Office Solicitation No.: 2020-002

1. Solicitation identified: This Addendum No. 2 applies to the following procurement solicitation:

Sewer Lateral Rehabilitation Term Contract
Purchasing Office Solicitation No.: 2020-002

2. Notice to Bidders publication date: **May 30, 2019**
3. Date Project Manual posted on City's website: **May 31, 2019**
4. Deadline for optional submittal in writing of questions seeking to revise or clarify any aspect of this procurement solicitation: **June 22, 2019, 2:00 p.m. Central Time**
5. Addendum No. 1 release date: **June 26, 2019**
6. Addendum No. 2 release date: **July 5, 2019**
7. Bids submittal deadline and scheduled opening: **July 9, 2019, 2:00 p.m. Central Time**
8. Tentative date of release of City's tabulation of bids received and notice of intent to award: **August 23, 2019**
9. Tentative date of award: Meeting of Board of Mayor and Aldermen at which is tentatively scheduled to be awarded the selection of the lowest and best responsive and responsible bid: **September 10, 2019**

10. Addendum:

In reference to the City of Franklin's May 31, 2019 Purchasing Office Solicitation No. 2020-002 for Sewer Lateral Rehabilitation Term Contract, the City has been asked certain questions about the solicitation by one or more vendors who are potential bidders.

The purpose of this Addendum No. 2 is to announce the City's responses to additional questions asked prior to the deadline for optional submittal in writing of questions seeking to revise or clarify any aspect of this procurement solicitation but which were inadvertently omitted by the City.

Please note that, by Addendum No. 1, the submittal deadline and scheduled opening of all bids received was postponed to:

July 9, 2019, 2:00 p.m. Central Time

City of Franklin Addendum No. 2 to

Purchasing Office Solicitation No.: 2020-002

Below are the additional questions asked prior to the deadline for questions and the City's responses thereto:

Q1: Will cleanouts be on the services or will "blind shots" be required?

A1: The City will provide cleanouts on the services. No blind shots are anticipated.

Q2: Do you have a range in the size of the host pipes we can anticipate?

A2: Primarily 8" and 10" but some 6".

Q3: Will these laterals be in lined or unlined pipe?

A3: The City plans to issue work orders for lateral work into areas where the City has just lined the main line. The majority should be in lined pipe. There will be instances where unlined pipe could come up but the City does not anticipate a significant amount.

Q4: Will permits / fee's be required from the city to perform this work?

A4: No permits or fees will be required. However, a \$1,000 deposit per hydrant meter will be required of the contractor for any water supplied from Franklin's water system.

11. Acknowledge addendum: Bidders shall acknowledge this addendum on their submitted Bid Form.

12. Questions: The deadline for optional submittal in writing of questions seeking to revise or clarify any aspect of this procurement solicitation has now passed. To ask questions of a procedural nature, please contact:

City of Franklin Purchasing Office
Franklin City Hall, Suite 107
109 3rd Ave. South
Franklin, TN 37064
purchasing@franklinton.gov
Tel: 615/550-6692
Fax: 615/550-0079

13. Communication with City during procurement phase: Any questions about either the content of or the procurement process pertaining to this procurement solicitation should be addressed as described above. Until the procurement award has been made, vendors shall not communicate about either the content of or the procurement process pertaining to this procurement solicitation with any official, employee or other representative of the City except through the City's Purchasing Office. The City reserves the right to disqualify any vendor that initiates unauthorized communication with the City during the procurement phase.