



SECTION A-A

NOTES

1. SIDEWALK CROSS SLOPE: 1.5% DESIRABLE, 2.0% MAX.
2. MINERAL AGGREGATE BASE: 4" MIN. THICK 303-01 MINERAL AGGREGATE, TYPE A BASE, GRADING D
3. CONCRETE: 4" MIN. THICK CLASS A (3,000 PSI, 6% AIR) WITH SYNTHETIC FIBER REINFORCEMENT, BROOM FINISH
4. EXPANSION JOINTS: SEE DRAWING RP-10
5. PROVIDE TRANSVERSE JOINTS FORMING BLOCKS AS NEARLY TO SQUARE AS PRACTICAL
6. PROVIDE A LONGITUDINAL JOINT CENTERED ON WALK WHERE SIDEWALK WIDTH IS 8'-0" OR GREATER

CONCRETE MULTI-USE PATH

DWG. NO.

RP-9



HISTORIC
FRANKLIN
TENNESSEE

CITY OF FRANKLIN

NOT TO SCALE

CITY
ENGINEER:

Paul P. Hoyle

DATE:

1/1/2020