



### PAVEMENT SCHEDULE

- ① 1.5" - BITUMINOUS SURFACE COURSE  
411-02.10 ACS MIX (PG 70-22) GRADING D RDWY
- ② TACK COAT  
403-01 BITUMINOUS MATERIAL FOR TACK COAT (TC) @0.07 GAL/SY (@0.10 GAL/SY MILLED SURFACES)
- ③ 2" - ASPHALT BINDER (226 LB/SY)  
307-02.08 ASPHALT CONCRETE MIX (PG 70-22) (BPMB-HM) GRADING B-M2
- ④ 4" - ASPHALTIC AGGREGATE BASE BINDER (460 LB/SY)  
307-02.01 ASPHALT CONCRETE MIX (PG 70-22) (BPMB-HM) GRADING A
- ⑤ 4" - ASPHALT AGGREGATE BASE (360 LB/SY)  
307-02.02 ASPHALT CONCRETE MIX (PG 70-22) (BPMB-HM) GRADING A-S  
307-02.03 AGGREGATE (BPMB-HM) GRADING A-S
- ⑥ PRIME COAT  
402-01 BITUMINOUS MATERIAL FOR PRIME COAT (PC) @0.30-0.35 GAL/SY  
402-02 AGGREGATE FOR COVER MATERIAL (PC) @8-12 LB/SY
- ⑦ 12" - MINERAL AGGREGATE BASE  
303-01 MINERAL AGGREGATE, TYPE A BASE, GRADING D
- ⑧ AGGREGATE UNDERDRAINS WITH PIPE (NOT SHOWN)  
(COORDINATE WITH TDOT STD. DRAWING RD-UD-3)

### NOTES

1. THICKNESSES SHOWN ARE MINIMUMS. FINAL DESIGN THICKNESS TO BE DETERMINED BY A GEOTECHNICAL ENGINEER.
2. REFERENCE "STANDARD SPECIFICATIONS FOR ROAD AND BRIDGE CONSTRUCTION" OF THE TENNESSEE DEPARTMENT OF TRANSPORTATION



HISTORIC  
FRANKLIN  
TENNESSEE

## MAJOR AND MINOR ARTERIAL PAVEMENT SECTION

CITY OF FRANKLIN

NOT TO SCALE

CITY  
ENGINEER:

*Paul P. Hoyle*

DATE:

1/1/2020

DWG. NO.

**RD-1**