



**HISTORIC
FRANKLIN
TENNESSEE**

February 12, 2020

Nashville Field Office
Tennessee Department of Environment and Conservation
711 R.S. Gass Boulevard
Nashville, TN. 37243

RE: Wet Weather Overflow: 135 Claude Yates Drive
NPDES Permit# TN0028827

On February 6, 2020 City of Franklin WRF personnel noticed a manhole overflowing at 7:40am. Water Department crews were dispatched to the location to estimate the volume of the overflow.

Franklin received 3.28 - inches of rainfall from February 4th through the 6th. At the time the overflow started the plant was operating at full capacity. The overflowing manhole was checked every hour until it ceased on February 7 at 2:30pm. The volume of the overflow was estimated at 476,200 gallons and will be reported as two exceedances.

This overflow was upstream of the WRF, indicating the hydraulic restrictions of the WRF may have attributed to this overflow. During the WRF upgrades project currently underway, the construction of a new headworks facility, in addition to the construction of an equalization basin, will help to alleviate the burden of the collection system and process higher capacities.

If you have any questions or comments, please let me know. I can be reached at (615) 794-4554 or at jr.lee@franklintn.gov

Sincerely,

A handwritten signature in black ink, appearing to read 'JR Lee'.

JR Lee
Assistant Service Division Superintendent